

Certificate
KA-26-1002



Issued	29/05/2026	Replaces	Original
Valid from	29/05/2026	Valid until	29/05/2029

Kiwa Approved - PFR Property Flood Resilience

Kiwa has determined that:

Larson Enterprises Ltd

Larson Lodge 1 Dingley Road Lindley Huddersfield HD3 3AY

Complies with BS 851188-1:2019+A1:2021 for the product(s) listed overleaf.

Signatures

Craig Devine
Technical Compliance Manager

Alpheo Mlotha CEng FIMMM MBA
Business Unit Manager

This certificate consists of 2 pages.
Disclosure of the certificate is permitted.



Kiwa Approved - PFR

The following product(s) have been assessed by Kiwa:

Product	Description	Installation Guide	Designated Maximum Water Depth
Buffalo Anti-Flood Air Brick	<p>An anti-flood air brick with a self-activating internal flood valve mechanism providing unobstructed airflow, compliant with BS 493:1995+A1:2010. The Product has a length of 215 mm, height of 67 mm and a depth of 55.5 mm.</p> <p>The Product can be installed in a single-brick arrangement.</p> <p>End users shall ensure that any mortar used to seal the air brick within the masonry wall is adequate and suitable for the conditions of the site.</p>	User, Installation & Maintenance Manual V3.2.1	540 mm